

CONCRETORS

GENERAL - s299-303 & 316-317 Work Health and Safety Regulation 2011	<ul style="list-style-type: none">• Work method statements available• Workers have construction induction training card• Crew size appropriate to work being undertaken e.g. 5-6 people
WORK AT HEIGHTS - s78-80; s306A-306O Work Health and Safety Regulation 2011 - Scaffolding Code of Practice 2009	<ul style="list-style-type: none">• Controls in place if risk of fall \geq 2m e.g. edge protection, catch platform• Under 2m: A risk assessment must be done ie: hazards identified, risk assessed, and control measures implemented (e.g: if someone can fall onto something that will injure them- control the risk.• Adequate work platforms provided and used• No gaps in perimeter protection• Penetrations covered/secured
TOOLS/ EQUIPMENT - s204-213; s214 & 215 Work Health and Safety Regulation 2011	<ul style="list-style-type: none">• Maintained in good condition• Used only for intended purpose• Guards in place when used
FALLING OBJECTS - s54-55 & s315B – 315M Work Health and Safety Regulation 2011	<ul style="list-style-type: none">• Workers not throwing up tools and materials• Mesh in place in scaffold• Exclusion zone and/or catch platform• Controls implemented for loads being lifted over adjoining areas e.g. adjoining area closed/gantry erected
ELECTRICAL - s90 Electrical Safety Regulation 2002	<ul style="list-style-type: none">• Electrical equipment kept away from water• Earth Leakage Switch installed on mains supply• Extension leads secured and protected from damage• Testing and tagging current
ACCESS HOUSEKEEPING - s314(a) & 315 Work Health and Safety Regulation 2011	<ul style="list-style-type: none">• Working area kept clear/tidy• Trip hazards managed e.g. material neatly stacked• Excess cement appropriately disposed e.g. designated areas
MANUAL TASKS - s60-61 Work Health and Safety Regulation 2011	<ul style="list-style-type: none">• High risk manual tasks identified e.g. continuous heavy lifting, excessive pulling/ pushing movements• Controls implemented for high risk manual tasks e.g. two persons carrying the concrete vibrator

<p>NOISE - s56-59 Work Health and Safety Regulation 2011 - Managing Noise and Preventing Hearing Loss at Work C.O.P</p>	<ul style="list-style-type: none"> • Hearing protection worn when operating concrete vibrators • Controls implemented to minimise exposure e.g. hearing protection, temporary sound absorption screens
<p>HAZARDOUS CHEMICALS - s341-346 & s351-358 Work Health and Safety Regulation 2011 - Hazardous Chemicals Code of Practice 2003</p>	<ul style="list-style-type: none"> • Safety Data Sheets (SDS) available for substances classified as hazardous (e.g. concrete klean) • Hazardous chemicals safely and securely stored when not in use • Workers trained in safe handling of hazardous chemicals (e.g. wear gloves when using acidic products) • Hazardous chemicals labelled (includes safety and risk phrases) • Hazardous chemicals not stored in food and/or drink containers (e.g. concrete klean not stored in drink bottles)
<p>PERSONAL PROTECTIVE EQUIPMENT - s44-47 Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> • Safety Data Sheets (SDS) available for substances classified as hazardous (e.g. concrete klean) • Hazardous chemicals safely and securely stored when not in use • Workers trained in safe handling of hazardous chemicals (e.g. wear gloves when using acidic products) • Hazardous chemicals labelled (includes safety and risk phrases) • Hazardous chemicals not stored in food and/or drink containers (e.g. concrete klean not stored in drink bottles)
<p>AMENITIES - s41; 42; 315A; Schedule 5A Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> • Sheltered meal area provided • Workers have access to toilets (1 toilet for each 15 workers or part thereof) • Hand and face washing facilities provided (separate from toilets) • Workers have access to potable, clean and cool drinking water • First aid equipment provided is hygienic and appropriate for the size and complexity of the project
<p>EMERGENCY PREPAREDNESS & RESPONSE - S43; Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> • Fire extinguishers available and testing current • Emergency evacuation plan available • Workers briefed on emergency evacuation plan